



- NOTES:**
1. ALL HYDRANT LATERALS SHALL BE DIP UNLESS OTHERWISE APPROVED BY SJWD, AND SHALL BE MECHANICALLY RESTRAINED FROM VALVE TO BURY.
 2. 6-IN DIAMETER DIP ALLOWED FOR LATERALS UP TO 18-FT IN LENGTH. IF OVER 18 LF USE 8-IN DIAMETER DIP.
 3. USE BOLLARD ONLY WHERE HYDRANT IS LESS THAN 5-FT BEHIND CURB OR LESS THAN 8-FT BEHIND PAVEMENT EDGE UNLESS OTHERWISE DIRECTED BY SJWD.

NO	DATE	REVISIONS	APP	BY



FILL -SLOPE FIRE HYDRANT

SAN JUAN WATER DISTRICT

APPROVED		
SCALE: NTS	PRINT DATE: 07/13/07	DETAIL NO. SHT 3 OF 27