

QUESTION AND ANSWERS**No. 1****July 21, 2021**

The following are questions and answers that have been submitted to date.

ANSWERS TO QUESTIONS		
	QUESTION	ANSWER
1	Will water be available to the contractor for washing the panels?	Ans.: There is no access to water at the solar facility, however the District will allow the contractor to fill their water buggy at the District's main site located at 9935 Auburn Folsom Road.
2	Is prevailing wage required for work completed at the site? Is the contractor required to Certify payroll?	Ans.: Yes, Prevailing wage is required for this effort. The Contractor is required to provide certified payroll if requested, however, the District will not require monthly reports.
3	Is the Contractor limited to providing a cell modem for the monitoring platform, or can we utilize the agency's ISP via Wifi or Ethernet connection?	Ans.: The Contractor is limited to cellular communications from the solar facility. Contractor is required to provide equipment necessary for communications to their operations center.
4	The RFP calls for 24/7 response to issues at the solar facility, can this be limited to Monday through Friday 8:00 AM to 4:00 PM?	Ans.: Weekend response is not required for this service. Weekday response is acceptable Monday through Friday 8:00 AM to 4:00 PM.
5	Can the District provide the quantity, make and model of the modules and inverters?	Ans.: Inverter A System: 1,360 Modules (8 Modules per string, 170 strings) Inverter B System: 1,136 Modules (8 Modules per string, 142 strings) Modules Make : Sun Power Model: SPR-318E-WHT-D Inverter Make: SATCON Model: PVS-375
6	Can the Contractors receive the plans for the existing system?	Ans.: See Attachment C
7	What is the expected response time when the system is off line due to an issues?	Ans.: Contractor is required to respond to solar field issues within 72 hours of receiving notice of a power production issue.

July 21, 2021

ATTACHMENT A
PRE-BID CONFERENCE SIGN-IN SHEET

**ATTACHMENT B
PRE-BID CONFERENCE PRESENTATION
(FOR REFERENCE ONLY)**

ATTACHMENT C
SOLAR FIELD RECORD DRAWINGS